



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599
www.miamidade.gov/economy

GAF
1 Campus Drive
Parsippany, NJ 07054

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable Building Code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TOPCOAT® Silicone HS Elastomeric Coating

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Gaspar J Rodriguez.



NOA No.: 15-0624.09
Expiration Date: 10/29/20
Approval Date: 10/29/15
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Material: Silicone

SCOPE:

This approves “**TOPCOAT® Silicone HS Elastomeric Coating**” as a roof maintenance coating as described in this Notice of Acceptance, designed to comply with the Florida Building Code, including the High Velocity Hurricanes Zone of the Florida Building Code.

MANUFACTURING LOCATIONS:

1. Waterford, NY

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies LLC	MPM-016-02-01	ASTM D 6694 Federal Specification TT-C-555B	05/20/15

PHYSICAL PROPERTIES OF COMPONENTS

Trade names: TOPCOAT® Silicone HS Elastomeric Coating

Thickness: See System Approvals Below

Specifications: ASTM D 6694

Description: A high solids, liquid applied silicone coating membrane applied at an application rate of:

- **Spray Polyurethane Foam Roofs:** Prepare surface as per manufacturer’s published instructions prior to coating. Apply TOPCOAT® Silicone HS Elastomeric Coating to achieve a minimum total thickness of 18 TDM (total dry mil).
- **Galvanized Steel Metal Roofs:** Prepare surface as per manufacturer’s published instructions prior to coating. Apply TOPCOAT® Silicone HS Elastomeric Coating to achieve a minimum total thickness of 18 TDM (total dry mil).
- **PVC Single Ply Membrane Roofs:** Prepare surface as per manufacturer’s published instructions prior to coating. Apply TOPCOAT® Silicone HS Elastomeric Coating to achieve a minimum total thickness of 18 TDM (total dry mil).
- **SBS Modified Bitumen Granule Roofs:** Prepare surface as per manufacturer’s published instructions prior to coating. Apply TOPCOAT® Silicone HS Elastomeric Coating to achieve a minimum total thickness of 18 TDM (total dry mil).

Container Size: 5 and 50 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with specific Roof Assembly Product Control Notice of Acceptance.



NOA No.: 15-0624.09
Expiration Date: 10/29/20
Approval Date: 10/29/15
Page 2 of 3

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. TOPCOAT® Silicone HS Elastomeric Coating shall not be applied in inclement weather conditions.
3. TOPCOAT® Silicone HS Elastomeric Coating shall not be applied over asphaltic shingles, metal shingles, fiber-cement shingles, quarry slate, cement or clay roofing tile, or wood shingles or shakes.
4. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their Roof Assembly Notice of Acceptance. Refer to applicable Building Code for requirements.
5. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



6. TOPCOAT® Silicone HS Elastomeric Coating shall only be applied by a factory trained and certified applicators and in accordance with manufacturer's published application instructions.
7. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami-Dade Product Control upon request.
8. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 15-0624.09
Expiration Date: 10/29/20
Approval Date: 10/29/15
Page 3 of 3